

## **Report on Market Operation Service Providers' Compliance**

**November 2014**

This report includes:

- The publication of the sections of the reports of the Pricing Manager, received in the previous month that relate to breaches of the Electricity Industry Participation Code (Code) by the Pricing Manager, as required by clause 13.214 of the Code
- the publication of the sections of the reports of the Clearing Manager, received in the previous month and to align with this report the current month that relate to breaches of the Code by the Clearing Manager, as required by clause 14.75 of the Code
- the republication of the sections of any reports of the Reconciliation Manager, received in the previous month that relate to breaches of the Code by the Reconciliation Manager under clause 15.33 of the Code<sup>1</sup>
- the republication of the sections of any reports of the FTR Manager, received in the previous month that relate to breaches of the Code by the FTR Manager
- any self-reported breaches of the Code by the Registry Manager for the previous calendar month
- any self-reported breaches of the Code by the Market Administrator for the previous calendar month<sup>2</sup>
- the publication of sections of the reports of the System Operator, received in the previous month that relate to breaches of the Code by the System Operator and the System Operator's discretionary action, that have been reported to the Market Administrator as required by clauses 13.102(2) and 13.102(1)(c) of the Code.

---

<sup>1</sup> Under clause 15.33 of the Code, the Authority must publish the sections of the reports that relate to an alleged breach of the Code by the Reconciliation Manager by 0930 hours on the business day following the day on which the Authority receives the report. These reports are available at <http://www.ea.govt.nz/industry/market/statistics-reports/reconciliation-manager-monthly-breach-reports/>

<sup>2</sup> The Code does not require the Market Administrator to publish any self-reported breaches of the Code by the Market Administrator. However, the Market Administrator has chosen to do so.

**Self-reported breaches by the Pricing Manager (under clause 13.213 of the Code)**

There were no self reported breaches by the Pricing Manager.

**Self-reported breaches by the Clearing Manager (under clause 14.74 of the Code)**

There were no self reported breaches by the Clearing Manager.

**Self-reported breaches by the Reconciliation Manager (under clause 15.30(1) of the Code)**

Note that this is a summary of the reconciliation manager monthly breach report which is published separately

There were no self-reported breaches by the Reconciliation Manager.

**Self-reported breaches by the FTR Manager (Not required by the Code)**

There were no self-reported breaches by the FTR Manager.

**Self-reported breaches by the Registry Manager (Not required by the Code)**

There were no self reported breaches by the Registry Manager.

**Self-reported breaches by the Market Administrator**

There were no self reported breaches by the Market Administrator.

**Self-reported breaches by the System Operator (under clause 13.102 (2) of the Code)**

There were no self-reported breaches by the System Operator.

**Discretionary action by the System Operator (under clause 13.102 (1) of the Code)**

<b>Time</b>	<b>Nature Of Divergence</b>	<b>Reason for Divergence</b>
11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 423 Start: 31-Oct-2014 11:04 End: 31-Oct-2014 11:30 Notes: Planned Tiwai offload Line 3, 190MW Last Dispatched Mw: 613
14:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 01-Nov-2014 14:04 End: 01-Nov-2014 14:30 Notes: Line 2 potline reduction. Last Dispatched Mw: 613
22:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 01-Nov-2014 22:03 End: 01-Nov-2014 22:30 Notes: Line2 off load 120MW Last Dispatched Mw: 613
22:47	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 01-Nov-2014 22:47 End: 01-Nov-2014 23:00 Notes: Line 3 Potline 120MW's Last Dispatched Mw: 613
04:06	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 02-Nov-2014 04:06 End: 02-Nov-2014 04:30 Notes: Line 2 offload 120MW Last Dispatched Mw: 613
11:06	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 435 Start: 02-Nov-2014 11:06 End: 02-Nov-2014 11:30 Notes: Line 2 planned offload of 178MW. Last Dispatched Mw: 613
15:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 03-Nov-2014 15:03 End: 03-Nov-2014 15:30 Notes:TWI L3 offload -120MW Last Dispatched Mw: 613
17:36	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 03-Nov-2014 17:36 End: 03-Nov-2014 18:00 Notes: Line 2 reduced load (120MW) Last Dispatched Mw: 613
02:06	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 498 Start: 04-Nov-2014 02:06 End: 04-Nov-2014 02:30 Notes: Line 3 planned reduction of 115MW Last Dispatched Mw: 613
10:15	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 498 Start: 04-Nov-2014 10:15 End: 04-Nov-2014 10:30 Notes: TWI L1 partial offload -115 MW Last Dispatched Mw: 613
01:06	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 436 Start: 05-Nov-2014 01:06 End: 05-Nov-2014 01:30 Notes: TWI line 1 offload. Last Dispatched Mw: 613
06:55	DISCRETION	SFD2201 SFD21 Discretion Clause 13.70, Part 13 ENR Max : 0 Start: 06-Nov-2014 06:55 End: 06-Nov-2014 07:00 Notes: Last Dispatched Mw: 105
11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 435 Start: 06-Nov-2014 11:04 End: 06-Nov-2014 11:30 Notes: Potline Line 2 (178MW) Last Dispatched Mw: 613
23:33	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 503 Start: 06-Nov-2014 23:33 End: 07-Nov-2014 00:00 Notes: TWI L2 offload 110 MW Last Dispatched Mw: 613
06:55	DISCRETION	ARG1101 BRR0 Discretion Clause 13.70, Part 13 ENR Max : 0 Start: 07-Nov-2014 06:55 End: 07-Nov-2014 07:30 Notes: ARG off for switching time for outage ARG_BLN_1 Last Dispatched Mw: 11.5

13:53	DISCRETION	ARG1101 BRR0 Discretion Clause 13.70, Part 13 ENR Max : 0 Start: 07-Nov-2014 13:53 End: 07-Nov-2014 14:30 Notes: ARG off for switching time for return of outage ARG_BLN_1 Last Dispatched Mw: 11
15:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 439 Start: 07-Nov-2014 15:03 End: 07-Nov-2014 15:30 Notes: Line 2 offload 179MW Last Dispatched Mw: 613
11:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 427 Start: 08-Nov-2014 11:03 End: 08-Nov-2014 11:30 Notes: TWI Line # 3 offload (186 MW) Last Dispatched Mw: 613
13:05	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 435 Start: 09-Nov-2014 13:05 End: 09-Nov-2014 13:30 Notes: Potline 2 reduction. Last Dispatched Mw: 613
13:30	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 495 Start: 09-Nov-2014 13:30 End: 09-Nov-2014 14:00 Notes: Potline 2 extended reduction, partially restored. Last Dispatched Mw: 435
13:07	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 311 Start: 10-Nov-2014 13:07 End: 10-Nov-2014 13:30 Notes: TWI reduction line 1. Last Dispatched Mw: 490
00:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 320 Start: 11-Nov-2014 00:04 End: 11-Nov-2014 00:30 Notes: emergency Potline 2 Last Dispatched Mw: 490
11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 426 Start: 12-Nov-2014 11:04 End: 12-Nov-2014 11:30 Notes: Line 3 offload (187MW) Last Dispatched Mw: 613
13:41	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 12-Nov-2014 13:41 End: 12-Nov-2014 14:00 Notes: Tiwai Planned offload Line 1 Last Dispatched Mw: 613
16:32	DISCRETION	TKA0111 TKA1 Discretion Clause 13.70, Part 13 ENR Max : 0 Start: 12-Nov-2014 16:32 End: 12-Nov-2014 17:00 Notes: TIM-TKA circuit tripped. Last Dispatched Mw: 12
11:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 435 Start: 17-Nov-2014 11:03 End: 17-Nov-2014 11:30 Notes: Potline - Line 1 (178MW) Last Dispatched Mw: 613
05:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 19-Nov-2014 05:03 End: 19-Nov-2014 05:30 Notes: Line 2 offload 120MW Last Dispatched Mw: 613
12:03	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 435 Start: 19-Nov-2014 12:03 End: 19-Nov-2014 12:30 Notes: Line 2 offload (178MW) Last Dispatched Mw: 613
02:06	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 493 Start: 20-Nov-2014 02:06 End: 20-Nov-2014 02:30 Notes: Potline reduction Line 1 (120 MW) Last Dispatched Mw: 613
14:31	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 20-Nov-2014 14:31 End: 20-Nov-2014 15:00 Notes: Potline #1 planned offload 180 MW. Last Dispatched Mw: 613
11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 436 Start: 21-Nov-2014 11:04 End: 21-Nov-2014 11:30 Notes: Planned offload line 1 177MW. Last Dispatched Mw: 613

11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 423 Start: 23-Nov-2014 11:04 End: 23-Nov-2014 11:10 Notes: Potline reduction, line 3, 190 MW Last Dispatched Mw: 613
01:53	DISCRETION	SFD2201 SPL0 Discretion Clause 13.70, Part 13 ENR Max : 140 Start: 24-Nov-2014 01:53 End: 24-Nov-2014 04:30 Notes: Constrained on for security reasons, required for morning peak. Last Dispatched Mw: 135
02:25	DISCRETION	SFD2201 SPL0 Discretion Clause 13.70, Part 13 ENR Min : 140 Start: 24-Nov-2014 02:25 End: 24-Nov-2014 04:30 Notes: Constrained on for security reasons, required for morning peak. Last Dispatched Mw: 135 Last Dispatched Mw: 140
11:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 25-Nov-2014 11:04 End: 25-Nov-2014 11:30 Notes: Potline line 1 (180MW) Last Dispatched Mw: 613
22:35	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 503 Start: 25-Nov-2014 22:35 End: 25-Nov-2014 23:00 Notes: Planned reduction Tiwai Line 3 Last Dispatched Mw: 613
00:33	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 27-Nov-2014 00:33 End: 27-Nov-2014 01:00 Notes: Emergency Tiwai potline 1. Last Dispatched Mw: 613
00:38	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 490 Start: 27-Nov-2014 00:38 End: 27-Nov-2014 01:00 Notes: Emergency Tiwai potline 1. Changed to partial offload. Last Dispatched Mw: 433
00:41	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 27-Nov-2014 00:41 End: 27-Nov-2014 01:00 Notes: Emergency Tiwai potline 1. Revised again to full offload. Last Dispatched Mw: 490
11:05	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 433 Start: 27-Nov-2014 11:05 End: 27-Nov-2014 11:30 Notes: Line 2 offload (180MW) Last Dispatched Mw: 613
14:00	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 310 Start: 28-Nov-2014 14:00 End: 28-Nov-2014 14:30 Notes: Potline #1 planned offload, 180 MW, at 14:05 Last Dispatched Mw: 490
17:04	DISCRETION	MAN2201 MAN0 Discretion Clause 13.70, Part 13 EN Max : 304 Start: 29-Nov-2014 17:04 End: 29-Nov-2014 17:30 Notes: Line 3 offload (186MW) planned off time at 17:05 Last Dispatched Mw: 490

This report was published by the Market Administrator on 19 December 2014. For further inquiries please contact the Market Administrator at the Electricity Authority or send an email to [marketoperations@ea.govt.nz](mailto:marketoperations@ea.govt.nz).