



Grid Emergency Report

To: GEN NZ Participants

Sent: 29-jan-2016 20:11

Ref: 1982783643

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

Cause:	Lightning in vicinity of Arapuni and Kinleith Waikato
At:	Arapuni, Kinleith
Starting:	29-jan-2016 18:05
Ending:	29-jan-2016 20:00
Action Taken:	The Arapuni split was closed due to lightning in the vicinity of the Arapuni-Kinleith circuits.

This notice is issued in accordance with Clause 13.97 (1), Part 13

A revision of this notice will be issued if there is any change to the situation above.

Limitation Of Liability/Disclaimer

Transpower make no representation or warranties with respect to the accuracy of the information contained in this document. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability of fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special incidental, consequential or other damages.