# ELECTRICITY INDUSTRY PARTICIPATION CODE DISTRIBUTED UNMETERED LOAD AUDIT REPORT

For

## NZTA OTAGO AND TRUSTPOWER

Prepared by: Rebecca Elliot

Date audit commenced: 23 March 2018

Date audit report completed: 23 May 2018

Audit report due date: 1 June 2018

## TABLE OF CONTENTS

Execu	tive summary	3
Audit	summary	4
	Non-compliances	/
	Recommendations	
	Issues 5	
1.	Administrative	ε
	1.1. Exemptions from Obligations to Comply with Code	6
	1.2. Structure of Organisation	
	1.3. Persons involved in this audit	7
	1.4. Hardware and Software	7
	1.5. Breaches or Breach Allegations	7
	1.6. ICP Data	7
	1.7. Authorisation Received	7
	1.8. Scope of Audit	8
	1.9. Summary of previous audit	8
	1.10. Distributed unmetered load audits (Clause 16A.26 and 17.295F)	8
2.	DUML database requirements	10
	2.1. Deriving submission information (Clause 11(1) of Schedule 15.3)	10
	2.2. ICP identifier and items of load (Clause 11(2)(a) and (aa) of Schedule 15.3)	11
	2.3. Location of each item of load (Clause 11(2)(b) of Schedule 15.3)	
	2.4. Description and capacity of load (Clause 11(2)(c) and (d) of Schedule 15.3)	
	2.5. All load recorded in database (Clause 11(2A) of Schedule 15.3)	13
	2.6. Tracking of load changes (Clause 11(3) of Schedule 15.3)	15
	2.7. Audit trail (Clause 11(4) of Schedule 15.3)	16
3.	Accuracy of DUML database	17
	3.1. Database accuracy (Clause 15.2 and 15.37B(b))	17
	3.2. Volume information accuracy (Clause 15.2 and 15.37B(c))	
Concl	usion	20
	Participant response	21

#### **EXECUTIVE SUMMARY**

This audit of the NZTA Otago (NZTA) Aurora network DUML database and processes was conducted at the request of Trustpower (Trustpower) in accordance with clause 15.37B. The purpose of this audit is to verify that the volume information is being calculated accurately, and that profiles have been correctly applied.

The audit was conducted in accordance with the audit guidelines for DUML audits version 1.1, which became effective on 1 June 2017.

The database is managed by Aurora and the data is held in their GIS system. Delta is the field contractor.

There is some inaccurate data within the database used to calculate submissions resulting in an estimated under submission of 46,200 kWh per annum.

The future risk rating of 14 indicates that the next audit be completed in 12 months and I agree with this recommendation. Four non-compliances were identified, and no recommendations were raised. The matters raised are detailed below:

#### **AUDIT SUMMARY**

## NON-COMPLIANCES

Subject	Section	Clause	Non-Compliance Controls		Audit Risk Rating	Breach Risk Rating	Remedial Action
Deriving submission informatio n	2.1	11(1) of Schedule 15.3	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum.  Incorrect ballasts applied resulting in an estimated under submission of 802.95 kWh.	Moderate	Medium	4	Identified
Description and capacity of load	2.4	11(2)(c) of Schedule 15.3	Ten items of load with incomplete lamp descriptions.	Moderate	Low	2	Identified
Database accuracy	3.1	15.2 and 15.37B(b)	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum.  Incorrect ballasts applied resulting in an estimated under submission of 802.95 kWh.	Moderate	Medium	4	Identified
Volume informatio n accuracy	3.2	15.2 and 15.37B(c)	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum. Incorrect ballasts applied resulting in an estimated under submission of 802.95 kWh.	Moderate	Medium	4	Identified
Future Risk R	lating					14	

Future risk rating	1-3	4-6	7-8	9-17	18-26	27+
Indicative audit frequency	36 months	24 months	18 months	12 months	6 months	3 months

## RECOMMENDATIONS

Subject	Section	Description	Remedial Action
		Nil	

## ISSUES

Subject	Section	Description	Issue
		Nil	

#### 1. ADMINISTRATIVE

#### 1.1. Exemptions from Obligations to Comply with Code

#### **Code reference**

Section 11 of Electricity Industry Act 2010.

#### **Code related audit information**

Section 11 of the Electricity Industry Act provides for the Electricity Authority to exempt any participant from compliance with all or any of the clauses.

#### **Audit observation**

The Electricity Authority's website was reviewed to identify any exemptions relevant to the scope of this audit.

#### **Audit commentary**

There are no exemptions in place relevant to the scope of this audit.

#### 1.2. Structure of Organisation

Trustpower provided a copy of their organisational structure.



#### 1.3. Persons involved in this audit

Auditor:

**Rebecca Elliot** 

**Veritek Limited** 

#### **Electricity Authority Approved Auditor**

Other personnel assisting in this audit were:

Name	Title	Company
Alan Miller	Corporate Account Manager	Trustpower
Delwyn Jeffrey	Commercial and Industrial Billing Manager	Trustpower
Richard Starkey	Commercial Development Manager	Aurora
Neville Hopkins	Assets System Team	Aurora
Suzanne Fraser	Contracts co-ordinator	Delta
Simeon Dwyer	Network Billing Analyst	Aurora

#### 1.4. Hardware and Software

The GIS database used for the management of DUML is managed by Aurora.

The database back up is in accordance with standard industry procedures. Access to the database is secure by way of password protection.

#### 1.5. Breaches or Breach Allegations

There are no breach allegations relevant to the scope of this audit.

#### 1.6. ICP Data

ICP Number	Description	NSP	Profile	Number of items of load	Database wattage (watts)
0000027638CECB5	Central Otago State Highways FKN0331	FKN0331	STL	315	69,619
0000486694CE943	Central Otago State Highways CYD0331	CYD0331	STL	223	36,468
0000486695CE506	Central Otago State Highways CML0331	CML0331	STL	85	16,825


#### 1.7. Authorisation Received

All information was provided directly by Trustpower and Aurora.

#### 1.8. Scope of Audit

The database is managed by Aurora and the data is held in their GIS system. Delta is the field contractor. Reports are received monthly by Trustpower.

The scope of the audit encompasses the collection, security and accuracy of the data, including the preparation of submission information based on the database reporting. The diagram below shows the audit boundary for clarity.



The audit was carried out at Aurora's premises in Cromwell on March 21<sup>st</sup>, 2018. The field audit was undertaken of 147 lights using the statistical sampling methodology.

### 1.9. Summary of previous audit

The previous audit was completed in September 2016 by Barry Harkerss of Trustpower. This audit found compliance with the code.

#### 1.10. Distributed unmetered load audits (Clause 16A.26 and 17.295F)

#### **Code reference**

Clause 16A.26 and 17.295F

#### **Code related audit information**

Retailers must ensure that DUML database audits are completed:

- 1. by 1 June 2018 (for DUML that existed prior to 1 June 2017)
- 2. within three months of submission to the reconciliation manager (for new DUML)
- 3. within the timeframe specified by the Authority for DUML that has been audited since 1 June 2017.

#### **Audit observation**

Trustpower have requested Veritek to undertake this streetlight audit.

## **Audit commentary**

This audit report confirms that the requirement to conduct an audit has been met for this database within the required timeframe. Compliance is confirmed.

#### 2. **DUML DATABASE REQUIREMENTS**

## 2.1. Deriving submission information (Clause 11(1) of Schedule 15.3)

#### **Code reference**

Clause 11(1) of Schedule 15.3

#### **Code related audit information**

The retailer must ensure the:

- DUML database is up to date
- methodology for deriving submission information complies with Schedule 15.5.

#### **Audit observation**

The process for calculation of consumption was examined.

#### **Audit commentary**

Trustpower reconciles this DUML load using the STL profile. The on and off times are derived from data logger information. Trustpower receive a monthly wattage report.

I recalculated the submissions for February 2018 using the data logger and the database information. I confirmed that the calculation method was correct, and the figures aligned.

There is some inaccurate data within the database used to calculate submissions. This is detailed in **sections 3.1** and **3.2**.

#### **Audit outcome**

Non-compliant

Non-compliance	Description						
Audit Ref: 2.1 With: Clause 11(1) of	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum.						
Schedule 15.3	Incorrect ballasts applied resulting in an estir	mated under submis	ssion of 802.95 kWh.				
	Potential impact: Medium						
	Actual impact: Medium						
	Audit history: None						
From: unknown	Controls: Moderate						
To: 30-Apr-18	Breach risk rating: 4						
Audit risk rating	Rationale for audit risk rating						
Medium	The controls are rated as moderate as they are will mitigate risk and remove errors most of the time.						
	The impact is assessed to be medium, ba above.	ased on the kWh o	differences described				
Actions to	aken to resolve the issue	Completion date	Remedial action status				
TRUS will work with Auro anomalies as required	ra to review and update the database	30/09/18	Identified				
Preventative actions take	en to ensure no further issues will occur	Completion date					
Validation of data to occu	ur as it comes in from the field	Ongoing					

## 2.2. ICP identifier and items of load (Clause 11(2)(a) and (aa) of Schedule 15.3)

#### **Code reference**

Clause 11(2)(a) and (aa) of Schedule 15.3

## **Code related audit information**

The DUML database must contain:

- each ICP identifier for which the retailer is responsible for the DUML
- the items of load associated with the ICP identifier.

## **Audit observation**

The database was checked to confirm an ICP is recorded for each item of load.

## **Audit commentary**

All items of load had an ICP recorded as required by this clause.

#### **Audit outcome**

## Compliant

### 2.3. Location of each item of load (Clause 11(2)(b) of Schedule 15.3)

#### **Code reference**

Clause 11(2)(b) of Schedule 15.3

#### **Code related audit information**

The DUML database must contain the location of each DUML item.

#### **Audit observation**

The database was checked to confirm the location is recorded for all items of load.

#### **Audit commentary**

The database contains either the nearest street address and Global Positioning System (GPS) coordinates for each item of load and users in the office and field can view these locations on a mapping system.

#### **Audit outcome**

Compliant

#### 2.4. Description and capacity of load (Clause 11(2)(c) and (d) of Schedule 15.3)

#### **Code reference**

Clause 11(2)(c) and (d) of Schedule 15.3

#### **Code related audit information**

The DUML database must contain:

- a description of load type for each item of load and any assumptions regarding the capacity
- the capacity of each item in watts.

#### **Audit observation**

The database was checked to confirm that it contained a field for lamp type and wattage capacity and included any ballast or gear wattage.

#### **Audit commentary**

The database contains three fields for lamp description, wattage, and "lamp losses". The lamp losses (ballast wattage) is expected to be a calculated figure which accounts for any variation from the input wattage and includes losses associated with ballasts. Examination of the database found all the wattages and lamp losses were populated for all items, but found ten items of load with incomplete lamp descriptions as detailed in the table below:

Lamp descriptions	Lamp Quantity
LED Lighting	1
Monument light, or ped cross, no beacons	2
Pedestrian crossing beacon with floodlights	4
Pedestrian crossing beacon without floodlights	2
Street name illuminator or Bollard	1

#### **Audit outcome**

Non-compliant

Non-compliance	Description					
Audit Ref: 2.4	Ten items of load with incomplete lamp descriptions.					
With: Clause 11(2)(c) of	c) of Potential impact: Low					
Schedule 15.3	Actual impact: Low					
	Audit history: None					
From: unknown	Controls: Moderate					
To: 30-Apr-18	Breach risk rating: 2					
Audit risk rating	Rationale for	audit risk rating				
Low	The controls are rated as moderate as they will mitigate risk and remove errors most of the time.					
	The impact is assessed to be low as only	ten items of load	are affected.			
Actions to	aken to resolve the issue	Completion date	Remedial action status			
TRUS will work with Auro anomalies as required	ra to review and update the database	30/09/18	Identified			
Preventative actions take	en to ensure no further issues will occur	Completion date				
Validation of data to occu	ır as it comes in from the field	Ongoing				

## 2.5. All load recorded in database (Clause 11(2A) of Schedule 15.3)

## **Code reference**

Clause 11(2A) of Schedule 15.3

## **Code related audit information**

The retailer must ensure that each item of DUML for which it is responsible is recorded in this database.

#### **Audit observation**

The field audit was undertaken of a statistical sample of 147 items of load on 21st March 2018.

## **Audit commentary**

The field audit findings are detailed in the table below:

Street	Database count	Field count	Light count differences	Wattage recorded incorrectly	Comments
Urban					
Alpha Street	2	2			
Ballarat Street	2	1	-1	1	1x 107W LED found in the field. Database has 2x 250W HPS recorded
Camp Street	1	1			
Centennial Avenue	45	45		4	4x pedestrian crossing lights with incorrect wattages
Golden Terrace	2	2			
Henderson Drive	3	3			
Humphrey Street	2	2			
Limerick Street	1	1			
Lucas Place	5	5			
Ripponvale Road	1	1			
Ross Street	2	1	-1		1x 70W HPS not found in field
Scotland Street	38	38		1	1x 400W MV changed to 107W LED
Shortcut Road	2	2			
Spruce Close	2	1	-1		1x 70W HPS not found in the field
Stanley Street	8	8		3	3x 250W HPS replaced with 107W LED
Tweed Street	1	1			
Rural					
Albert Town-Lake Hawea Road	3	3			
Aubrey Road	1	1			

Street	Database count	Field count	Light count differences	Wattage recorded incorrectly	Comments
Cromwell-Clyde Road	6	6			
Main Road	7	7			
Old Bridge Road	2	2		1	160W MV not present. 70W HPS found
Reid Avenue	1	1			
Tarras-Cromwell Road	2	2			
Templeton Street	3	3			
Willoughby Place	5	5			
Grand Total	147	142	3	10	

No additional items of load were found in the field. The field audit variances found are recorded as non-compliance in **section 3.1**.

#### **Audit outcome**

Compliant

#### 2.6. Tracking of load changes (Clause 11(3) of Schedule 15.3)

#### **Code reference**

Clause 11(3) of Schedule 15.3

#### Code related audit information

The DUML database must track additions and removals in a manner that allows the total load (in kW) to be retrospectively derived for any given day.

#### **Audit observation**

The process for tracking of changes in the database was examined.

#### **Audit commentary**

Any changes that are made during any given month take effect from the beginning of that month. The information is available which would allow for the total load in kW to be retrospectively derived for any day. On 20 September 2012, the Authority sent a memo to retailers and auditors advising that tracking of load changes at a daily level was not required if the database contained an audit trail. I have interpreted this to mean that the production of a monthly "snapshot" report is sufficient to achieve compliance.

The database is managed by Aurora and the data is held in their GIS system. Delta carry out all fault and maintenance work. Any changes made in the field are passed to Aurora to update the database.

Aurora advised there have been no new connections made during the audit period. Currently work packages are provided to Aurora for new developments but these are not passed to the GIS team to load until the work is complete and signed off. This can be sometime after electrical connection has occurred. The new connection process is under review to improve the timeliness and accuracy of the data going into the database.

There is no plan for an LED rollout, but LEDs are sometimes used to replace existing lamps in the field on a reactive basis.

Delta carries out outage patrols in the urban areas as part of their patrols for Queenstown Lakes DC and Central Otago DC.

No festive lighting is connected to the Aurora NZTA unmetered streetlight network.

#### **Audit outcome**

Compliant

#### 2.7. Audit trail (Clause 11(4) of Schedule 15.3)

#### **Code reference**

Clause 11(4) of Schedule 15.3

#### Code related audit information

The DUML database must incorporate an audit trail of all additions and changes that identify:

- the before and after values for changes
- the date and time of the change or addition
- the person who made the addition or change to the database

#### **Audit observation**

The database was checked for audit trails.

#### **Audit commentary**

A complete audit trail of all additions and changes to the database information.

#### **Audit outcome**

Compliant

#### 3. ACCURACY OF DUML DATABASE

#### 3.1. Database accuracy (Clause 15.2 and 15.37B(b))

#### **Code reference**

Clause 15.2 and 15.37B(b)

#### **Code related audit information**

Audit must verify that the information recorded in the retailer's DUML database is complete and accurate.

#### **Audit observation**

The DUML Statistical Sampling Guideline was used to determine the database accuracy. The table below shows the survey plan.

Plan Item	Comments	
Area of interest	NZTA Otago on the Aurora network	
Strata	The database contains items of load Otago Aurora network area.	
	The area has two distinct sub groups of urban and rural.	
	The processes for the management of NZTA Aurora Otago items of load are the same, but I decided to place the items of load into two strata, as follows:	
	<ol> <li>Urban</li> <li>Rural.</li> </ol>	
Area units	I created a pivot table of the roads in each area and I used a random number generator in a spreadsheet to select a total of 25 sub-units.	
Total items of load	147 items of load were checked.	

Wattages were checked for alignment with the published standardised wattage table produced by the Electricity Authority.

#### **Audit commentary**

The database was found to contain some inaccuracies.

The field data was 90.9% of the database data for the sample checked. The total wattage recorded in the database for the sample was 29,108 watts. The estimated total wattage found in the field for the sample checked was 26,405 watts, a difference of 2,703 watts. This will result in an estimated over submission of 46,200 kWh per annum (based on annual burn hours of 4,271 as detailed in the DUML database auditing tool).

Wattages for all items of load were checked against the published standardised wattage table produced by the Electricity Authority in the database and found errors. I calculated the impact on submission if these were used for submission and estimate minor under submission of 802.95 kWh per annum.

#### **Audit outcome**

#### Non-compliant

Non-compliance	Description				
Audit Ref: 3.1 With: Clause 15.2 and	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum.				
15.37B(b)	Incorrect ballasts applied resulting in an estimated under submission of 802.95 kWh.				
	Potential impact: Medium				
	Actual impact: Medium				
From: unknown	Audit history: None				
To: 30-Apr-18	Controls: Moderate				
	Breach risk rating: 4				
Audit risk rating	Rationale for audit risk rating				
Medium	The controls are rated as moderate as they are will mitigate risk and remove errors most of the time.  The impact is assessed to be medium, based on the kWh differences described above.				
Actions taken to resolve the issue		Completion date	Remedial action status		
TRUS will work with Aurora to review and update the database anomalies as required		30/09/18	Identified		
Preventative actions taken to ensure no further issues will occur		Completion date			
Validation of data to occu	ır as it comes in from the field	Ongoing			

#### 3.2. Volume information accuracy (Clause 15.2 and 15.37B(c))

#### **Code reference**

Clause 15.2 and 15.37B(c)

## **Code related audit information**

The audit must verify that:

- volume information for the DUML is being calculated accurately
- profiles for DUML have been correctly applied.

#### **Audit observation**

The submission was checked for accuracy for the month the database extract was supplied. This included:

- checking the registry to confirm that all ICPs have the correct profile and submission flag
- checking the database extract combined with the burn hours against the submitted figure to confirm accuracy.

## **Audit commentary**

Trustpower reconciles this DUML load using the STL profile. The on and off times are derived from data logger information. Trustpower receive a monthly wattage report.

I recalculated the submissions for February 2018 using the data logger and the database information. I confirmed that the calculation method was correct, and the figures aligned.

There is some inaccurate data within the database used to calculate submissions. This is detailed in sections 2.1 and 3.1.

#### **Audit outcome**

#### Non-compliant

Non-compliance	Description				
Audit Ref: 3.2 With: Clause 15.2 and	The database accuracy is assessed to be 90.9% indicating an estimated over submission of 46,200 kWh per annum.				
15.37B(c)	Incorrect ballasts applied resulting in an estir	ct ballasts applied resulting in an estimated under submission of 802.95 kWh.			
	Potential impact: Medium				
	Actual impact: Medium				
From: unknown	Audit history: None				
To: 30-Apr-18	Controls: Moderate				
	Breach risk rating: 4				
Audit risk rating	Rationale for audit risk rating				
Medium	The controls are rated as moderate as they are will mitigate risk and remove errors most of the time.  The impact is assessed to be medium, based on the kWh differences described				
Actions taken to resolve the issue		Completion date	Remedial action status		
TRUS will work with Aurora to review and update the database anomalies as required		30/09/18	Identified		
Preventative actions taken to ensure no further issues will occur		Completion date			
Validation of data to occu	ır as it comes in from the field	Ongoing			

## CONCLUSION

The database is managed by Aurora and the data is held in their GIS system. Delta is the field contractor.

There is some inaccurate data within the database used to calculate submissions resulting in an estimated under submission of 46,200 kWh per annum.

The future risk rating of 14 indicates that the next audit be completed in 12 months and I agree with this recommendation. Four non-compliances were identified, and no recommendations were raised.

## PARTICIPANT RESPONSE

Trustpower will work with Aurora to identify and correct current anomalies in the database, as well as to validate new items as they are added.