

Report on market operation service providers' compliance

June 2018

This report includes:

- the publication¹ of the sections of the reports that relate to breaches of the Electricity Industry Participation Code (Code) by the pricing manager, received by the Authority in the previous calendar month
- the republication² of the sections of the reports that relate to breaches of the Code by the clearing manager, received by the Authority in the previous calendar month
- the republication³ of the sections of the initial report that relate to breaches of the Code by the reconciliation manager, received by the Authority in the current calendar month
- the republication of the sections of the report that relate to breaches of the Code by the FTR manager, received by the Authority during the previous calendar month
- the republication of the sections of the report that relate to breaches of the Code by the registry manager, received by the Authority during the current calendar month
- the republication of sections of the report that relate to breaches of the Code by the system operator and the system operator's discretionary action, received by the Authority in the previous month.

¹ As required by clause 13.214 of the Code

² As required by clause 14.69 of the Code

³ Clause 15.33 of the Code requires the Authority to publish the sections of the reports that relate to an alleged breach of the Code by the reconciliation manager by 1630 hours on the 2nd business day following the day on which the Authority receives the report. These reports are available at <http://www.ea.govt.nz/industry/market/statistics-reports/reconciliation-manager-monthly-breach-reports/>.

Self-reported breaches by the pricing manager (under clause 13.213 of the Code)

There were no self-reported breaches by the pricing manager.

Self-reported breaches by the clearing manager (under clause 14.68 of the Code)

There were no self-reported breaches by the clearing manager.

Self-reported breaches by the reconciliation manager (under clause 15.30(1) of the Code)

The reconciliation manager has breached Clause 15.14 (3) of the Code due to incomplete information because of a participant breach.

Self-reported breaches by the FTR manager (Not required by the Code)

There were no self-reported breaches by the FTR manager.

Self-reported breaches by the registry manager (Not required by the Code)

There were no self-reported breaches by the registry manager.

Self-reported breaches by the system operator (under clause 3.14)

Two breaches were reported in May by the system operator. The first relates to a change to offer which was not acknowledged correctly and was not then used in the forward looking schedules, this error reached real time causing a market impact of less than \$500. The second relates to a modelling error that removed a generator's offers from the forward looking schedules, this was identified before real time and corrected before dispatch.

Discretionary action by the system operator (under clause 13.102)

Event Date & Time
Event Description

Discretionary action by the system operator (*under clause 13.102*)

05-Apr-2018 11:42:41
MAN2201 MAN0 Tiwai Aluminium Smelter line 2 extended offload.

09-Apr-2018 11:56:33
MAN2201 MAN0 Restoration of extended potline

09-Apr-2018 12:02:05
MAN2201 MAN0 Restoration of extended potline.

10-Apr-2018 07:19:52
KPA1101 KPI1 OPK_KPI_SFD tripping

10-Apr-2018 07:50:38
HWA1101 PTA1 HAW bus islanded.

10-Apr-2018 07:50:54
HWA1101 PTA2 HAW bus islanded.

10-Apr-2018 07:51:12
HWA1101 PTA3 HAW bus islanded

10-Apr-2018 12:53:15
HLY2201 HLY2 HLY 2 tripping.

12-Apr-2018 07:38:33
WHI2201 WHI0 : Required for System Security

12-Apr-2018 07:46:00
WHI2201 WHI0 : Required for System Security

12-Apr-2018 18:06:39
WHI2201 WHI0 : End of Discretion

12-Apr-2018 18:08:01
WHI2201 WHI0 : End of Discretion

16-Apr-2018 15:30:28
MAN2201 MAN0 To provide capacity for reduction line restoration

19-Apr-2018 11:37:39
MAN2201 MAN0 Extended potline line 2

19-Apr-2018 15:43:33
HLY2201 HLY6 Huntly 6 tripped.

This report was published by the Authority on 21 June 2018. For further inquiries please contact the Electricity Authority via email to marketoperations@ea.govt.nz.