VERITEK

Electricity Industry Participation Code Audit Report

For

Trustpower Limited



Ashburton District Council Distributed Unmetered Load

Prepared by Rebecca Elliot – Veritek Ltd

Date of Audit: 06/10/17

Date Audit Report Complete: 23/03/18

Executive Summary

This audit of the Ashburton District Council (ADC) DUML database and processes was conducted at the request of Trustpower Limited (Trustpower), in accordance with clause 15.37B. The purpose of this audit is to verify that the volume information is being calculated accurately, and that profiles have been correctly applied.

The audit was conducted in accordance with the audit guidelines for DUML audits version 1.1, which became effective on 1 June 2017.

ADC is located on the Electricity Ashburton network. Electricity Ashburton is engaged as the streetlighting maintenance contractor. ADC maintains the RAMM database and reporting from this is used by Trustpower to calculate submission information.

ADC have good processes in place for the management of the street light database. The audit identified 625 items of load with the incorrect ballast applied. 586 of these relate to one lamp type with a minor difference of 2 watts and therefore this should be easy to remedy. This results in an estimated under submission of 5,901 kWh per annum.

The field audit of 334 items of load found five differences, resulting in the survey wattage being 0.21% higher than the database wattage. This results in an estimated under submission of 3,178 kWh per annum.

The future risk rating of ten indicates that the next audit be completed in 12 months and I agree with this recommendation. The matters raised are detailed below:

Table of Non-Compliance

Subject	Section	Clause	Non-compliance	Controls	Audit Risk Rating	Breach Risk Rating	Remedial Action
Deriving submission	2.1	11(1) of Schedule 15.3	Under submission of 15.04 kWh per month due to the rounding of the unmetered load kW figure to the nearest whole number Accuracy ratio is 100.21% indicating under submission of 3,178 kWh per annum.	Moderate	Low	2	Identified
			625 items of load with the incorrect ballast applied indicating under submission of 5,901 kWh per annum.				
			Combined value of 9,079 kWh under submitted per annum				

Subject	Section	Clause	N	on-compliance	Controls	Audit Risk Rating	Breach Risk Rating	Remedial Action
Recording of all load	2.5	11(2A) of Schedule 15.3	2 lights field.	s not found in the	Moderate	Low	2	Identified
Tracking of load change	2.6	11(3) of Schedule 15.3		n festival lights are uded in reporting to wer	Moderate	Low	2	Investigating
Database accuracy	3.1	Clause 15.2 & 15.37(b)	100.21	cy ratio is % indicating under ssion of 3,178 kWh num.		Low	2	Investigating
			incorre indicat	ms of load with the ct ballast applied ing under ssion of 5,901 kWh num.				
				ned value of 9,079 nder submitted.				
Volume information accuracy	3.2	Clause 15.2 & 15.37(c)	15.04 I due to the uni figure t	submission of kWh per month the rounding of metered load kW to the nearest number	Moderate	Low	2	Identified
			100.21	cy ratio is % indicating under ssion of 3,178 kWh num.				
			incorre indicat	ms of load with the ct ballast applied ing under ssion of 5,901 kWh num.				
				ned value of 9,079 nder submitted per				
					Future I	Risk Rating		10
					Indicative Audit	Frequency	12	2 months
Future risk	0	1	<u>-</u> Λ	5-8	Q ₋ 15	16-1	0	10⊥

Future risk rating	0	1-4	5-8	9-15	16-18	19+
Indicative audit frequency	36 months	24 months	18 months	12 months	6 months	3 months

Table of Recommendations

Subject	Section	Recommendation	Description
Data transmission	1.10	20 of schedule 15.2	Add password protection to the monthly report.
Tracking of load change	2.6	11(3) of schedule 15.3	Field check that the light type provided in the as builts is what is installed in the field.

Persons Involved in This Audit:

Auditor:

Rebecca Elliot Veritek Limited Electricity Authority Approved Auditor

Other personnel assisting in this audit were:

Name	Title	Company
Barry Harkerss	Account Manager	Trustpower
Deborah Barron	Asset Manager Officer Roading	Ashburton District Council
Wayne Watson	Projects Manager	Electricity Ashburton

Contents

Execu	utive Summary	2
Table	of Non-Compliance	2
Table	of Recommendations	4
Perso	ons Involved in This Audit:	5
Conte	ents	6
1.	Administrative	7
1.1	List of ICPs	7
1.2	Exemptions from Obligations to Comply with Code (Section 11 of Electricity Industry Act 2010)	7
1.3	Supplier List	7
1.4	Hardware and Software	8
1.5	Breaches or Breach Allegations	8
1.6	Distributed Unmetered Load Audits (Clauses 16A.26 & 17.295F)	8
1.7	Separate Distributed Unmetered Load Audit (Clause 16A.8(4))	9
1.8	Summary of Previous Audit	9
Table	of Non-Compliance	9
Table	of Recommendations	9
1.9	Scope of Audit	10
1.10	Data Transmission (Clause 20 of Schedule 15.2)	11
2.	DUML database requirements	11
2.1	Deriving Submission Information (Clause 11(1) of Schedule 15.3)	11
2.2	ICP Identifier (Clause 11(2)(a) of Schedule 15.3)	13
2.3	Location of Each Item of Load (Clause 11(2)(b) of Schedule 15.3)	13
2.4	Description of Load Type (Clause 11(2)(c) & (d) of Schedule 15.3)	13
2.5	All load recorded in database (Clause 11(2A) of Schedule 15.3)	13
2.6	Tracking of Load Changes (Clause 11(3) of Schedule 15.3)	15
2.7	Audit Trail (Clause 11(4) of Schedule 15.3)	17
3.	Accuracy of DUML database	17
3.1	Database Accuracy (Clause 15.2 & 15.37(b))	17
3.2	Volume Information Accuracy (Clause 15.2 & 15.37(c))	19
4.	Conclusions	21
5.	Trustpower Comments	22

1. Administrative

1.1 List of ICPs

The following ICP is relevant to the scope of this audit:

ICP	Description	NSP	No. of items of load
0000010559EAD7C	Ashburton District Council – Streetlighting	ASB0331	27
0000025163EA218	Ashburton District Council – Streetlighting	ASB0331	2,856
0000025164EAFD2	Open Spaces - Parks and Amenities	ASB0331	94
0000030218EA553	Methven	ASB0661	27
0000033381EAF01	NZTA Methven	ASB0331	55
0000033382EA3C1	NZTA not Methven	ASB0331	299
	TOTA	AL items of load	3,358

1.2 Exemptions from Obligations to Comply with Code (Section 11 of Electricity Industry Act 2010)

Section 11 of the Electricity Industry Act provides for the Electricity Authority to exempt any participant from compliance with all or any of the clauses.


Trustpower confirms there are no exemptions in place relevant to the scope of this audit:

1.3 Supplier List

Ashburton DC, Electricity Ashburton and RAMM are considered agents under this clause, and Trustpower clearly understands that the use of agents does not release them from their compliance obligations.

A contractual relationship exists between Trustpower and Ashburton DC as part of the sales contract, however there is no direct contractual relationship between Trustpower and Electricity Ashburton and RAMM for the provision of services in relation to DUML. This is not seen as an issue, if the processes for updating the database are robust and have appropriate validation controls in place.

The diagram below shows the relationships from a compliance and contractual perspective.



1.4 Hardware and Software

The SQL database used for the management of DUML is remotely hosted by RAMM Software Ltd. The database is commonly known as "RAMM" which stands for "Roading Asset and Maintenance Management".

Ashburton DC confirmed that the database back-up is in accordance with standard industry procedures. The database is password protected.

1.5 Breaches or Breach Allegations

There are no breach allegations relevant to the scope of this audit.

1.6 Distributed Unmetered Load Audits (Clauses 16A.26 & 17.295F)

Retailers must ensure that DUML database audits are completed:

- 1. by 1 June 2018 (for DUML that existed prior to 1 June 2017)
- 2. within three months of submission to the reconciliation manager (for new DUML)
- 3. within the timeframe specified by the Authority for DUML that has been audited since 1 June 2017.

Audit Observation

Trustpower has requested Veritek to undertake this streetlight audit.

Audit Commentary

This audit report confirms that the requirement to conduct an audit has been met for this database within the required timeframe. Compliance is confirmed.

1.7 Separate Distributed Unmetered Load Audit (Clause 16A.8(4))

Retailers must ensure that DUML audits are reported in a separate audit report.

Audit Observation

Trustpower has requested Veritek to undertake this streetlight audit.

Audit Commentary

The audit report for this DUML database is separate from other audit reports. Compliance is confirmed.

1.8 Summary of Previous Audit

Trustpower provided a copy of the last audit report undertaken by Steve Woods of Veritek in 2014. The findings from that audit are set out below with the current statuses.

Table of Non-Compliance

Subject	Section	Clause	Non compliance	Status
ICP identifiers	2.2.1 now 2.2	11(2)(a) of schedule 15.3	EA spreadsheet does not record ICP identifiers.	Cleared
Capacities	2.2.4 now 2.4	11(2)(d) of schedule 15.3	Wattage figures not correct for 5 lamps. Wattage figures not correct for 5 of lamps. Lamp wattage not populated for 766 records in ADC database.	Still existing
Audit trail	2.4 now 2.7	11(4) of schedule 15.3	EA spreadsheet does not contain an audit trail.	Cleared

Table of Recommendations

Subject	Section	Clause	Recommendation for improvement	Status
Data transmission	1.9	20 of schedule 15.2	Transmit monthly reports in a secure manner when reporting from ADC commences.	Still existing
Tracking of load changes	2.3	11(3) of schedule 15.3	Check database accuracy for new developments. Conduct a complete field audit of all lamps.	Still existing Cleared


1.9 Scope of Audit

This audit of the Ashburton District Council (ADC) DUML database and processes was conducted at the request of Trustpower Limited (Trustpower), in accordance with clause 15.37B. The purpose of this audit is to verify that the volume information is being calculated accurately, and that profiles have been correctly applied.

The audit was conducted in accordance with the audit guidelines for DUML audits version 1.1, which became effective on 1 June 2017.

ADC is located on the Electricity Ashburton network. Electricity Ashburton is engaged as the streetlighting maintenance contractor and ADC maintain the RAMM database, which is used by Trustpower to calculate submission information. ADC provides reporting to Trustpower on a monthly basis.

The scope of the audit encompasses the collection, security and accuracy of the data, including the preparation of submission information based on the monthly reporting. The diagram below shows the flow of information and the audit boundary for clarity.



The audit was carried out at ADC 's premises on 06/10/17. The field audit was undertaken of 334 lights using the statistical sampling methodology. The field selection included four population groups:

- Urban
- Rural
- NZTA
- New lights.

1.10 Data Transmission (Clause 20 of Schedule 15.2)

A report is sent to Trustpower monthly from ADC. This is not password protected. I recommend a password is added.

Recommendation	Description	Audited party comment	Remedial action
Regarding: Clause 20 of	Add password protection to the	Discussed with ADC who believe	Declined
schedule 15.2	monthly report.	the security inherent within their,	
		and Trustpower's, email and	
		internet software and information	
		systems meets the requirement of	
		this clause.	
		Password-protected documents	
		introduce issues of their own, where	
		the password must either be	
		remembered or recorded (in itself a	
		security problem) by all users.	
		Change of roles and/or staff can	
		easily render passwords forgotten	
		or lost.	
		This recommendation is declined at	
		this stage	

2. DUML database requirements

2.1 Deriving Submission Information (Clause 11(1) of Schedule 15.3)

The retailer must ensure the:

- DUML database is up to date
- methodology for deriving submission information complies with Schedule 15.5.

Audit Observation

The process for calculation of consumption was examined.

Audit Commentary

Trustpower reconciles this DUML load using the STL profile. Trustpower derives the hours of operation information using a data logger. I checked the submission figures for the month of September 2017 and found a variance between the calculated kWh figure and the figures submitted. The combined impact of this was an under submission of 15.04 kWh for the month of August. This is due to GTV rounding the unmetered figure to the nearest full number. Trustpower have put a fix in place for this so all streetlight ICPs will round to three decimal places and this will be washed through the revision process.

As detailed in **section 3.1**, the DUML database auditing tool provided a result indicating the field data was 100.21% of the database data. This will result in estimated under submission by 3,178 kWh per annum. Analysis of the ADC identified 625 items of load with the incorrect ballast applied. The incorrect capacities would result in an estimated under submission of 5,900.98 kWh per annum (based on 11.5 hours burn hours for 365 days).

The combined estimated under submission for ADC is 9,079 kWh per annum.

This is recorded as non-compliance below.

Non-compliance	Des	scription			
Audit Ref: 2.1 With: 11(1) of Schedule	Under submission of 15.04 kWh per month due to the rounding of the unmetered load kW figure to the nearest whole number				
15.3	Accuracy ratio is 100.21% indicating under submission of 3,178 kWh per annum.				
From: entire audit period	625 items of load with the incorrect ballast applied indicating under submission of 5,901 kWh per annum.				
l rom one addit ponda	Combined value of 9,079 kWh under subm	nitted per annum.			
	Potential impact: Low				
	Actual impact: Low				
	Audit history: None				
	Controls: Moderate				
	Breach risk rating: 2				
Audit risk rating	Rationale for audit risk rating				
Low	Controls are rated as moderate, as they ar but there is room for improvement.	re sufficient to mitigate the risk most of the time			
	The combined variance of 9,079 kWh under audit risk rating is low.	er submitted is cons	idered minor therefore the		
Actions tal	ken to resolve the issue	Completion date	Remedial action status		
	correct the upload file from rounding to ata has been backdated for the 14 month	13/03/18	Identified		
ADC are working with Electricity match the EA standards	Ashburton to update ballasts in the database to	31/03/18			
Preventative actions taker	n to ensure no further issues will occur	Completion date			
	udit on the RAMM data comparing listed ations. Discrepancies will be discussed with ed as required.	Ongoing			

2.2 ICP Identifier (Clause 11(2)(a) of Schedule 15.3)

The DUML database must contain:

- each ICP identifier for which the retailer is responsible for the DUML
- the items of load associated with the ICP identifier.

Audit Observation

The database was checked to confirm the correct ICP was recorded against each item of load.

Audit Commentary

The analysis found that all items of load had the correct ICP recorded against them. Compliance is confirmed.

2.3 Location of Each Item of Load (Clause 11(2)(b) of Schedule 15.3)

The DUML database must contain the location of each DUML item.

Audit Observation

The database was checked to confirm the location is recorded for all items of load.

Audit Commentary

The database contains Global Positioning System (GPS) coordinates for 3.336 (99.34%) of the 3,358 lamps. Street address information is recorded for all lamps. Compliance is confirmed.

2.4 Description of Load Type (Clause 11(2)(c) & (d) of Schedule 15.3)

The DUML database must contain:

- a description of load type for each item of load and any assumptions regarding the capacity
- the capacity of each item in watts.

Audit Observation

The database was checked to confirm that it contained a field for lamp type and wattage capacity, and included any ballast or gear wattage.

Audit Commentary

The database contains a field for lamp type and this is populated appropriately. The database contains three fields for wattage, firstly the manufacturers rated wattage, secondly the gear wattage and the third contains the total wattage. All items of load had this detail populated. Compliance is confirmed.

2.5 All load recorded in database (Clause 11(2A) of Schedule 15.3)

The retailer must ensure that each item of DUML for which it is responsible is recorded in this database.

Audit Observation

The field audit was undertaken of 213 lights using the statistical sampling methodology.

Audit Commentary

The field audit findings are detailed in the table below and found a small number of discrepancies.

Street	Database	Field	Light	Wattage	Comments
	count	count	count	recorded	
			differences	incorrectly	
ADC Urban			unierences	lincorrectly	
ALTON PLACE	3	3	_	_	
DAVIS CRESCENT	13	13	-	-	
KING STREET	7	7	-	-	
MILLER STREET	9	9			
	15	15	-	-	
OAK GROVE EAST			-	-	
ORCHARD GROVE	4	4	-	-	
PRINCES STREET	23	23	-	-	
WALSHS STREET	5	5	-	-	
WOODHAM DRIVE	5	5	-	-	
ALLENS ROAD	23	23	-	-	
BELT ROAD	20	20	-	-	
TUCKER STREET	10	10	-	-	
TURTON STREET	9	9	-	-	
ADC New					
BRAEBROOK DRIVE	16	16			
PRIMROSE PLACE	4	4	_	-	
DOUGLAS DRIVE	8	8	_	_	
HANRAHAN STREET	18	18	-	_	
CHARLESWORTH DRIVE	17	17	-	_	
AYERS GREEN	5	5	_	-	
ADC- Rural		<u> </u>			
ALFORD PLACE	2	2	_	_	I
ALFORD PLACE			-	-	1 additional light found in
CAWTON GROVE	4	5	+1		field 35m from end of road
HAKATERE DRIVE EXT	3	3	-	-	
JAMES STREET (HINDS)	4	2	-2		2 lights not found in the field
PATON STREET	3	3	-	-	
RACECOURSE AVENUE	11	11	-	-	
REED STREET	8	8	-	-	
THOMSON STREET	27	27	-	-	
TRENT PLACE	1	2	+1		1 additional light found in the field but may be plotted inaccurately in RAMM
NZTA	1	<u> </u>	<u> </u>	1	
SH1 CHERTSEY TO ASHBURTON	10	11	+1		1 additional light found in field
SH1 ASHBURTON TO HINDS	35	35	-	-	
SH1 ASHBURTON TO					
RANGITATA	12	12	-	-	
Total	334	335	5		

Compliance is not achieved.

Non-compliance	Description		
Audit Ref: 2.5	2 lights not found in the field.		
With: Clause 11(2A) of	Potential impact: Low		
Schedule 15.3	Actual impact: Low		
	Audit history: None		
From: Entire audit period	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	Controls are rated as moderate, as they are sufficient to mitigate the risk most of the time but there is room for improvement.		
	Overall the database accuracy was high hence the audit risk rating of low.		
Actions taken to resolve the issue		Completion date	Remedial action status
ADC have undertaken to investigate discrepancies and update where required		31/03/18	Identified
Preventative actions taken to ensure no further issues will occur		Completion date	
ADC are undertaking audits and improving maintenance to capture discrepancies		Ongoing	

2.6 Tracking of Load Changes (Clause 11(3) of Schedule 15.3)

The DUML database must track additions and removals in a manner that allows the total load (in kW) to be retrospectively derived for any given day.

Audit Observation

The process for tracking of changes in the database was examined.

Audit Commentary

Any changes that are made during any given month take effect from the beginning of that month. The information is available which would allow for the total load in kW to be retrospectively derived for any day. On 20 September 2012, the Authority sent a memo to Retailers and auditors advising that tracking of load changes at a daily level was not required if the database contained an audit trail. I have interpreted this to mean that the production of a monthly "snapshot" report is sufficient to achieve compliance.

As changes occur Electricity Ashburton provides the information to ADC, and this information is then entered into the database. The database is checked for accuracy as part of the lamp replacement process.

For new subdivisions, of which there are few, the lighting information is provided by the developer to ADC as part of the vesting process. They are added to RAMM prior to livening and will not be livened until the Council has given their approval. It is at this point that they are added to the monthly reporting

to Trustpower. ADC accept that the as builts are what is installed in the field. I recommend that a check in the field is added to confirm that this is correct.

Recommendation	Description	Audited party comment	Remedial action
Regarding: Clause 11(3) of schedule 15.3	Field check that the light type provided in the as builts is what is installed in the field.	Vested Streetlight data will be sent to Electricity Ashburton for verification before loading into RAMM as part of ADC's vesting procedures.	Identified

Festival lights were discussed and there are some used in the Methven area but these are not being included in the reporting to Trustpower. This is recorded as non-compliance below.

Non-compliance	Description		
Audit Ref: 2.6	Methven festival lights not included in reporting to Trustpower.		
With: Clause 11(3) of	Potential impact: Low		
Schedule 15.3	Actual impact: Low		
	Audit history: None		
From: Entire audit period	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	Controls are rated as moderate, as they are sufficient to mitigate the risk most of the time but there is room for improvement.		
	The volume associated with the festival lights is minor and therefore the audit risk rating of low.		
Actions taken to resolve the issue		Completion date	Remedial action status
Vested Streetlight data will be sent to Electricity Ashburton for verification before loading into RAMM as part of ADC's vesting procedures.		As data is received	Investigating
ADC are investigating the festival lights to confirm if they are metered or unmetered, if they are the Council's lights or belong to other non-council groups and when they are in use (Winter Festival and Holiday season). Once this is determined processes will be put in place to include these lights in the database where needed.			
Preventative actions taken to ensure no further issues will occur		Completion date	
Included in ADC Vesting procedures.		Ongoing	

2.7 Audit Trail (Clause 11(4) of Schedule 15.3)

The DUML database must incorporate an audit trail of all additions and changes that identify:

- the before and after values for changes
- the date and time of the change or addition
- the person who made the addition or change to the database.

Audit Observation

The database was checked for audit trails.

Audit Commentary

ADC demonstrated a complete audit trail of all additions and changes to the database information. Compliance is confirmed.

3. Accuracy of DUML database

3.1 Database Accuracy (Clause 15.2 & 15.37(b))

The Audit must verify that the information recorded in the retailer's DUML database is complete and accurate.

Audit Observation

The DUML Statistical Sampling Guideline was used to determine the database accuracy. The table below shows the survey plan.

Plan Item	Comments	
Area of interest	Ashburton DC region	
Strata	The database contains items of load in Ashburton and	
	included the NZTA lighting in the area.	
	The area has three distinct sub regions of Ashburton urban,	
	Ashburton rural, new lights and NZTA.	
	The processes for the management of Ashburton DC items	
	of load are the same, but I decided to place the items of load	
	into three strata, as follows:	
	1. ADC urban	
	2. ADC urban	
	3. ADC new	
	4. NZTA	
Area units	I created a pivot table of the roads in each area and I used	
	a random number generator in a spreadsheet to select a	
	total of 32 subunits (roads)	
Total items of load	334 items of load were checked.	

The database was examined for light wattage and ballast accuracy.

Audit Commentary

The DUML database auditing tool provided a result indicating the field data was 100.21% of the database data. This will result in estimated under submission by 3,178 kWh per annum.

I checked the ballasts being applied and found a small number of discrepancies when compared to the standardised wattage table. These are detailed in the table below:

Lamp Туре	RAMM Total Wattage	EA Standardised Wattage	Variance	Database Quantity	Estimated Annual kWh effect on consumption
Philips Cosmos 60W	71	66	5	20	419.7
100W HPS SON	112	114	2	586	4,918.88
250W HPS SON	260	278	10	15	629.55
400W HPS SON	442	438	-4	4	-67.15
Total estimated annual effect on submission				5,900.98	

Analysis of the ADC identified 625 items of load with the incorrect ballast applied. The incorrect capacities would result in an estimated under submission of 5,901 kWh per annum (based on 11.5 hours burn hours for 365 days).

The combined estimated under submission for ADC is 9,079 kWh per annum.

This is recorded as non-compliance below.

Non-compliance	Description		
Audit Ref: 3.1	Accuracy ratio is 100.21% indicating under submission of 3,178 kWh per annum.		
With: 15.2 & 15.37(b)	625 items of load with the incorrect ballast applied indicating under submission of 5,901 kWh per annum.		
From: entire audit period	Combined value of 9,079 kWh under submitted per annum.		
Trom. entire dadit period	Potential impact: Low		
	Actual impact: Low		
	Audit history: None		
	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	Controls are rated as moderate, as they are sufficient to mitigate the risk most of the time but there is room for improvement.		
	The combined variance of 9,079 kWh under submitted is considered minor therefore the audit risk rating is low.		
Actions taken to resolve the issue		Completion date	Remedial action status
ADC have undertaken to investigate discrepancies and update where required		31/03/18	Investigating
Preventative actions taken to ensure no further issues will occur		Completion date	
Included in ADC Vesting procedures.		Ongoing	

3.2 Volume Information Accuracy (Clause 15.2 & 15.37(c))

The audit must verify that:

- volume information for the DUML is being calculated accurately
- profiles for DUML have been correctly applied.

Audit Observation

The submission was checked for accuracy for the month the database extract was supplied. This included:

- checking the registry to confirm that the ICP has the correct profile and submission flag
- checking the database extract combined with the burn hours against the submitted figure to confirm accuracy.

Audit Commentary

I compared the total submission to the reconciliation manager for each ICP to a manual calculation based on the database information provided, and burn hours. Trustpower reconciles this DUML load using the STL profile. Trustpower derives the hours of operation information using a data logger. I checked the submission figures for the month of September 2017 and found a variance between the calculated kWh figure and the figures submitted. The combined impact of this was an under submission of 15.04 kWh for the month of August. This is due to GTV rounding the unmetered figure to the nearest

full number. Trustpower have put a fix in place for this so all streetlight ICPs will round to three decimal places and this will be washed through the revision process.

As detailed in **sections 3.1**, the DUML database auditing tool provided a result indicating the field data was 100.21% of the database data. This will result in estimated under submission by 3,178 kWh per annum. Analysis of the ADC identified 625 items of load with the incorrect ballast applied. The incorrect capacities would result in an estimated under submission of 5,900.98 kWh per annum (based on 11.5 hours burn hours for 365 days).

The combined estimated under submission for ADC is 9,079 kWh per annum.

This is recorded as non-compliance below.

Non-compliance	Description		
Audit Ref: 3.1 With: 15.2 & 15.37(c)	Under submission of 15.04 kWh per month due to the rounding of the unmetered load kW figure to the nearest whole number		
With 13.2 & 13.37(c)	Accuracy ratio is 100.21% indicating under submission of 3,178 kWh per annum.		
From: entire audit period	625 items of load with the incorrect ballast applied indicating under submission of 5,901 kWh per annum.		
	Combined value of 9,079 kWh under subm	nitted per annum.	
	Potential impact: Low		
	Actual impact: Low		
	Audit history: None		
	Controls: Moderate		
	Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
Low	Controls are rated as moderate, as they are sufficient to mitigate the risk most of the time but there is room for improvement.		
	The combined variance of 9,079 kWh under submitted is considered minor therefore the audit risk rating is low.		
Actions taken to resolve the issue		Completion date	Remedial action status
A fix has been put in place to correct the upload file from rounding to the nearest whole number. Data has been backdated for the 14 month washup cycle.		13/03/18	Identified
ADC are working with Electricity Ashburton to update ballasts in the database to match the EA standards		31/03/18	
Preventative actions taken to ensure no further issues will occur		Completion date	
ADC will run an internal annual audit on the RAMM data comparing listed ballasts with the EA recommendations. Discrepancies will be discussed with Electricity Ashburton and corrected as required.		Ongoing	

4. Conclusions

ADC have good processes in place for the management of the street light database. The audit identified 625 items of load with the incorrect ballast applied. 586 of these relate to one lamp type with a minor difference of 2 watts and therefore this should be easy to remedy. This results in an estimated under submission of 5,900.98 kWh per annum.

The field audit of 334 items of load found five differences, resulting in the survey wattage being 0.21% higher than the database wattage. This results in an estimated under submission of 3,178 kWh per annum.

The future risk rating of eight indicates that the next audit be completed in 12 months and I agree with this recommendation.

5. Trustpower Comments

Trustpower has reviewed this report and their comments are recorded within it. No further comments were provided.